



Stavelly Water Treatment Plant Alberta, Canada Manganese Removal Using MPSF Technology



Design constraints and objectives

- Town of 700 people.
- Groundwater supply not under direct influence of surface water.
- Manganese above 0.05 mg/L (as high as 0.4 mg/L), hydrogen sulfide (detectable odor) and presence of sulfate reducing bacteria.
- Required treatment capacity of 1,200m³/day or 50,000 litres per hour.
- Minimum chemical requirements.
- Minimum level of automation.
- Minimum complexity – Operator Level 1 if possible.
- Backwash water to be disposed of in town lagoon through existing sanitary sewer.

Process flow diagram for Mn removal.



- 6 (4 m x 4 m) cells
- Each cell can treat a maximum of 10,000 L/h (Loading of 0.6 m³/m²/h)

